The 10<sup>th</sup> CTWWA/JWWA/WRF Water System Seismic Conference

Verification and Evaluation Method for the Seismic Performance of Potable Water Mains Lined with Cured-in-place Pipe (CIPP)

> Hiromasa ISHIZEKI Chief Engineer, Potable Water Products PALTEM, Ashimori Industry Co., Ltd.

# Why we do this? – CIPP (Cured-in-place pipe)



Ashimori property and confidential

### Why we do this? – CIPP, example of PALTEM



## Agenda

# 1. Why we do this

- 2. Past performance of CIPP in seismic areas
- 3. Loading test on pipe specimen with CIPP
- 4. Verification by calculation

## Why we do this? - Industrial background

## Seismic standards for trenchless pipe rehab

• Sewer

Level 1 & 2 classification and performance criteria for CIPP

• Gas

CIPP standardized for sealing purpose in earthquakes

• Potable water

CIPP installation record not enough for standardization

## Agenda

1. Why we do this

# 2. <u>Past performance of CIPP in</u> <u>seismic areas</u>

- 3. Loading test on pipe specimen with CIPP
- 4. Verification by calculation

### 370 km of our liners were used in...



### **Past performance – cross-checking**

	Year	Earthquakes	S	Max. intensity	Mw	
	Jan/17/1995	Great Hansh	Great Hanshin		6.9	
	Oct/06/2000	West Tottor	West Tottori		6.8	
	Oct/23/2004	Chuetsu	Chuetsu		6.6	
	Mar/25/2007	Noto	Noto		6.7	
	Jul/16/2007	Chuetsu Offsh	Chuetsu Offshore		6.6	
	Mar/11/2011	Tohoku		7	9.0	
PALTEM CIPPs installed in						
Municipalities stricken by intensity 6+ <u>6,690 m</u> Areas in which liquefactions						

### No failure reports

## Agenda

- 1. Why we do this
- 2. Past performance of CIPP in seismic areas
- 3. Loading test on pipe specimen with <u>CIPP</u>
- 4. Verification by calculation

## **Before testing – understanding CIPP**



# <u>Characteristics of CIPP suppress</u> <u>pullout phenomena of host pipe</u> <u>during earthquakes</u>

### **Before testing – understanding joint pullout**

$$R = \sigma_{2L} \times A = \frac{\pi \cdot D \cdot \tau \cdot L}{2A} \times A$$

- *R* : Pullout force at joint
- A: Sectional area
- D: Outside diameter of pipe
- $\tau$ : Friction between pipe and ground (=0.0098 N/mm<sup>2</sup>)
- L: Length of pipe

#### No joint pullout should occur when friction forces are...

Ground and existing pipe (approx. 0.01 N/mm<sup>2</sup>) Existing pipe and CIPP (0.025 ~ 1.000 N/mm<sup>2</sup>)

(JWWA)

# **Testing – loading test, preparation**



# **Testing – loading test, execution**

Hydrau



DIP300A x 6 m x 2 (Mortar lined) Internal water pressure 0.75 MPa

evel-2 EQ load x 2

ad applied 60 kN

lype-k joint

Ashimori property and confidential

# Testing – loading test result, no joint pullout

CI	PP	"Super-HL" Ф300, t=4.0 mm			
Host	t pipe	DIP, Ф300 mm, L=6,000 mm x 2			
Spec	cimen	No.1	No.2	No.3	
	Close-fitting	$\checkmark$	$\checkmark$	$\checkmark$	
CIPP's properties	Expansion	$\checkmark$	$\checkmark$	✓	
	Adhesion	-	-	-	
Load	applied	60 kN (Estimated seismic load <sup>1)</sup> w/ s.f. 2)			
1) JWWA					

# No joint displacement, leak or damage under 60 kN

# **Testing – forcing joint pullout**



# DIP 300A x 6 m x 2, type-K joint (Mortar lined)



# **Testing – forcing joint pullout**

	Test I (SP, 4 m)		Test Ⅱ(DIP, 12 m)	
Direction of displacement	Comp.	Tensile	Tensile	
Max. displacement (mm)	50	58	210	
A) Max. load applied (kN)	16	65	427	
B) Estimated seismic load (kN) <sup>1)</sup>	9.	23	27.69	
A∕B	appro	x. 18x	approx. 15x	

1) JWWA

- <u>15 times the estimated seismic load was needed</u> <u>to generate joint displacement</u>
- No leaks or damages resulted from displacement

## Agenda

- 1. Why we do this
- 2. Past performance of CIPP in seismic areas
- 3. Loading test on pipe specimen with CIPP
- 4. <u>Verification by calculation</u>

# **Verification – selecting calculation conditions**

## Based on observation, CIPP within jointed pipeline is



### **Calculation conditions for CIPP within host pipeline**

	CIPP	SP
Structural classification	Continuous pipe	
Joint	Ignored	No joint
Slippage between host pipe and ground	Ignored	Considered
Tensile elastic modulus	CIPP	SP
Allowable strain setting	CIPP	SP

## Verification – allowable strain for Level-1 EQ

# Dynamic property ≤ Elastic range

0.6% strain (equivalent to Level-1 seismic motion) cyclically applied for 300 times at the speed of 5 mm/min





## Verification – allowable strain for Level-1 EQ

# **Determined to be 0.6%**



# Water-tightness to be maintained under plasticization

1.2% strain (Level-2 equivalent) cyclically applied for 100 times on 5 Hz frequency.

Input strain	Specimen	Specimen status after testing	Tensile strength after testing (MPa)
	1	No damage	Avg. 137
1.2%	2		↓ No strenath
	3		deterioration
-	4	_	140



# For Level-2, 1.2%

# Verification – in a model ground condition

Depth to the center of the pipe (h')



<sup>(</sup>JWWA)

# Verification – in a model ground condition

		Level-1	Level-2	
	Design internal pressure	0.152%		
Normalland	Vehicle load	0.046%		
Normarioau	Temperature change	0.015%		
	Unbalanced subsidence	0.010%		
Seismic load	c load 0.060% 0.502%		0.502%	
Тс	otal strain in axial direction	0.283%	0.725%	
	Allowable strain	0.600%	1.200%	
	Result of verification	Within Allowable strain	Within Allowable strain	



# **Test proved past performance**

# Pipe with CIPP behaves like continuous pipe

# **Calculation method selected for CIPP**

Ashimori property and confidential



# Future challenge still remains

# Contact: Hiromasa Ishizeki hiomasa\_ishizeki@ashimori.co.jp